



## **ELECTRICAL CODE CLARIFICATION**

700 N. TRYON STREET CHARLOTTE, NC 28202

(704) 336-2831

**SUBJECT:** BUS DUCT CLEARANCES

**CODE REFERENCE:** 110.26 NEC 2005

**SUBMITTED BY:** Electrical Department (PLAN REVIEW)

**EFFECTIVE DATE:** Immediately

**PROBLEM:** Are working clearances required on large busways (bus duct)?

**DATE:** 8-30-07

**SOLUTION:** No clearances are required if there are no spaces for plug-ins.  
In sections that allow plug-ins proper clearances are required for the plug-ins.

**APPROVED BY: GERALD HARVELL ELECTRICAL CPM**

*Gerald Howell*